



LABORATORY REPORT

Page 1 of 1

Client: Adtech Environmental
Address: 4 Adrian Place
BALGOWLAH HEIGHTS
NSW 2093
Attention: Boyd Keogh
Email: boyd@keoghtech.com and greg@keoghtech.com

Sample Description: Beaudesert – WTP.

Taken By: *Laboratory Staff
Date Taken: 11/02/2004
Date Taken: 11/02/2004

Test	Units	Method	Results	
			Raw Water	Treated Water
Faecal coliforms (membrane presumptive)	cfu/100m L	B1	26,000	<1
Total coliforms	cfu/100m L	B12	--	<1
E.coli (membrane presumptive)	cfu/100m L	B12	--	<1

Samples have been taken in accordance with AS5667:98 – Water Quality - Sampling.
All pages of this Report have been checked and approved.

Remarks: * Tweed Laboratory Centre Staff took independent samples from respective raw and treated water outlets, whilst the treatment plant was operated under supervision of Adtech staff.

This Report replaces the Report issued on 24 February 2004 (remarks changed).

Dr PJ Wright
(Senior Technical Officer)

Date of Report: 26 February 2004